

Mayde Creek MUD

2024 Drinking Water Quality Report

DEAR CUSTOMER:

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The sources of drinking water (both tap water and bottled water) generally include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791). Contaminants that may be present in the source water include:

1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. 2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. 3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. 4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems. 5) Radioactive contaminants, which can be naturally- occurring or be the result of oil and gas production and mining production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the district's operator, Inframark.

You may be more vulnerable than the general population to certain microbial contaminants such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV / AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Mayde Creek MUD receives surface water from the West Harris County Regional Water Authority as the primary source of water that comes from the City of Houston. In addition, Mayde Creek MUD has 2 groundwater wells located within Harris County which draw water from Gulf Coast Aquifer.

TCEQ completed an assessment of your source water, and results indicate that our sources have a low susceptibility to contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protections efforts at our system contact Bart Downum, Inframark, at (713-822-1457).

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following: <http://www.tceq.texas.gov/gis/swaview>

Further details about sources and source water assessments are available in Drinking Water Watch at the following URL: <http://dww2.tceq.texas.gov/DWWW/>

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water. The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices.

Public input concerning the water system may be made at regularly scheduled meetings, generally held at 6:00 PM on the 4th Monday of the month at 19600 Misty Cove, Katy, TX 77449. You may also contact Bart Downum, Inframark, at 713-822-1457 with any concerns or questions you may have regarding this report.

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al tel. (281) 579-4507.

Mayde Creek MUD has completed an inventory of our water service lines and determined that our water system does not have any lead, galvanized requiring replacement, or unknown service lines. Mayde Creek MUD has found no evidence of the use of lead service lines (i) in the system records, including distribution system maps and drawings, (ii) when reading water meters or performing maintenance activities during normal system operations, or (iii) during visual inspection of the service line.

Definitions & Abbreviations:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

AVG: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 assessment: Study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 assessment: Very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL: Million Fibers per Liter (a measure of asbestos).

Mrem: millirems per year (a measure of radiation absorbed by the body).

N/A: Not applicable.

NTU: Nephelometric Turbidity Units (a measure of turbidity).

pCi/L: Picocuries per liter (a measure of radioactivity).

ppb: micrograms per liter or parts per billion.

ppm: milligrams per liter or parts per million.

ppq: Parts per quadrillion, or picograms per liter (pg/L).

ppt: Parts per trillion, or nanograms per liter (ng/L).

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Substance	Unit of Measure	Year	MCL	Average Level Detected	Min - Max Level Detected	MCLG	In Compliance	Typical Sources
Radioactive Contaminants (Regulated at the Water Plant)								
Combined Radium	pCi/L	2022	5	1.76	1.76 - 1.76	0	Yes	Erosion of natural deposits.
Gross Alpha	pCi/L	2022	15	6.2	6.2 - 6.2	0	Yes	Erosion of natural deposits.
Gross Beta	pCi/L	2022	50	4.6	4.6 - 4.6	0	Yes	Decay of natural and man-made deposits.
Synthetic Organic Contaminants Including Pesticides and Herbicides								
Atrazine	ppb	2024	3	0.1	0.1 - 0.1	3	Yes	Runoff from herbicide used on row crops.
Unregulated Contaminants								
Bromodichloromethane	ppb	2024	N/A	9.5	9.5 - 9.5	N/A	Yes	By-product of drinking water disinfection.
Chloroform	ppb	2024	N/A	19.0	19 - 19	N/A	Yes	By-product of drinking water disinfection.
Dibromochloromethane	ppb	2024	N/A	3.4	3.4 - 3.4	N/A	Yes	By-product of drinking water disinfection.
Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.								
Inorganic Contaminants (Regulated at the Water Plant)								
Arsenic	ppb	2022	10	2.6	2.6 - 2.6	0	Yes	Erosion of natural deposits; runoff from orchards; runoff from glass, and electronics production wastes.
Barium	ppm	2022	2	0.13	0.13 - 0.13	2	Yes	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Fluoride	ppm	2023	4	0.24	0.24 - 0.24	4	Yes	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate	ppm	2024	10	0.28	0.28 - 0.28	10	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Disinfectant Byproducts								
Haloacetic Acids (HAA5)	ppb	2024	60	22.9	22.9 - 22.9	N/A	Yes	By-product of drinking water disinfection.
Total Trihalomethanes	ppb	2024	80	31.2	31.2 - 31.2	N/A	Yes	By-product of drinking water disinfection.

Substance	Unit of Measure	Year	MRDL	Average Level Detected	Min - Max Level Detected	MRDLG	In Compliance	Typical Sources
Maximum Residual Disinfectant Level								
Chlorine Residual	ppm	2024	4.0	2.25	2.04 - 2.51	4.0	Yes	Water additive used to control microbes.

Substance	Unit of Measure	Year	90th % Value	EPA Action Level	Results above Action Level	MCLG	In Compliance	Typical Sources
Lead and Copper (Regulated at Customers Tap)								
Copper	ppm	2024	0.122	1.3	0	1.3	Yes	Corrosion of household plumbing systems, erosion of natural deposits; leaching from wood preservatives.
Lead	ppb	2024	2.18	15	0	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits.

Our Water System Received Water From
Ricewood MUD for 45 days in September due to facility maintenance.
Water Quality Results are Listed Below

Substance	Unit of Measure	Year	MCL	Average Level Detected	Min - Max Level Detected	MCLG	In Compliance	Typical Sources
Radioactive Contaminants (Regulated at the Water Plant)								
Gross Beta	pCi/L	2021	50	4.1	4.1 - 4.1	0	Yes	Decay of natural and man-made deposits.
Synthetic Organic Contaminants Including Pesticides and Herbicides								
Atrazine	ppb	2022	3	0.13	0.13 - 0.13	3	Yes	Runoff from herbicide used on row crops.
Simazine	ppb	2022	4	0.07	0.07 - 0.07	4	Yes	Herbicide runoff.
Unregulated Contaminants								
Manganese	ppm	2022	N/A	0.0043	0.004 - 0.004	N/A	Yes	Abundant naturally occurring element.
Dibromochloromethane	ppb	2023	N/A	2.0	2 - 2	N/A	Yes	By-product of drinking water disinfection.
Bromodichloromethane	ppb	2024	N/A	13.0	13 - 13	N/A	Yes	By-product of drinking water disinfection.
Bromoform	ppb	2024	N/A	1.5	1.5 - 1.5	N/A	Yes	By-product of drinking water disinfection.
Chloroform	ppb	2024	N/A	31.0	31 - 31	N/A	Yes	By-product of drinking water disinfection.
Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.								
Inorganic Contaminants (Regulated at the Water Plant)								
Barium	ppm	2022	2	0.06	0.06 - 0.06	2	Yes	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Cyanide	ppb	2023	200	70.0	70 - 70	200	Yes	Discharge from plastic and fertilizer factories; discharge from steel/metal factories.
Fluoride	ppm	2024	4	0.2	0.2 - 0.2	4	Yes	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate	ppm	2024	10	0.27	0.27 - 0.27	10	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

* All levels detected were below the MCLs.